

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170823-EX2534  
**Report Reference** EX2534-19671004  
**Issue Date** 2017-AUGUST-23

**Issued to:** GRISWOLD INDUSTRIES, DBA CLA-VAL CO  
1701 PLACENTIA AVE  
COSTA MESA CA 92627

**This is to certify that  
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES,  
PRESSURE REDUCING AND PRESSURE CONTROL  
TYPE

Pilot-operated pressure-control valves are intended to  
reduce the water pressure in the supply piping for standpipe  
systems for fire protection service,  
Models - 90G-21, 90A-21

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Pilot-Operated Pressure-Control Valves for Fire-Protection  
Service, UL1739

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

